

Allen Family Foods, Inc.

Allen Family Foods, Inc.

Phone:
FAX:
email:

April 18, 2008

Mr. Allen McCloskey
Department of Natural Resources & Environmental Control
Division of Water Resources
89 Kings Highway
Dover, Delaware 19901



Re: Permit #DE 0000299
Discharge 001

This letter is to follow up the 24 hour phone verification with your office that occurred on April 15, 2008 concerning the Oil and Grease grab sample results for the sampling period on March 25, 2008. Per the notification requirements of Part II, Section A.2.(b) of the referenced permit we report the following:

Allen's - Harbeson 001 Oil and Grease Grab Samples

Sample Dates	Parameter	Results Reported
3-25-08 @ 0700 hours	Oil and Grease Grab #1	10.3 mg/L
3-25-08 @ 1100 hours	Oil and Grease Grab #2	6.1 mg/L
3-25-08 @ 1500 hours	Oil and Grease Grab #3	<5.0 mg/L
Arithmetic mean		<7.13 mg/L
March, 2008	Oil and Grease Average lbs/day	<68.9 lbs/day

It is suspected that an analytical error on the part of our contract laboratory may have occurred on the samples taken at 0700 and 1100 hours causing results that exceeded the detection limit of 5.0 mg/L. It should be noted that Total Suspended Solids on the composite sample for this particular sampling period was 1.8 mg/L and BOD was <3.0 mg/L. The quality of the composite sample for this period was very good with it unlikely that permit limit of 68.0 average lbs/day was exceeded.

If you should have any questions, please do not hesitate to contact me at (302) 684-1640,
Ext. 184.

Respectfully submitted,
ALLEN FAMILY FOODS, INC.

A handwritten signature in black ink, reading "Michael R. Sause". The signature is written in a cursive style with a large, stylized "M" and "S".

Michael R. Sause
Wastewater Manager

cc: Tom Brinson